



BIG SPRING SCHOOL DISTRICT
Building and Grounds Department
43 Mount Rock Road
Newville, PA 17241
(717) 776-2000 Ext. 1603

TO : Karen Ward, Principal
FROM : Joshua Putt, HVAC Technician/Asbestos Supervisor
SUBJECT: Mount Rock Elementary Semi-Annual Asbestos Update
DATE : Jul 1, 2018
CC : Dr. Richard Fry, Superintendent

In accordance with state and federal asbestos management guidance, I have compiled all available data during the last six months (December 31, 2017 – July 1, 2018). During this time I have found that the asbestos has remained basically intact for the last six months.

On November 20th of 2017, CA Laboratories, Inc. tested the window caulking and glazing for asbestos. Both the caulking and glazing were found to contain no asbestos materials. The VCT floor was tested by CA Laboratories, Inc. on Dec 21 2017 and tested positive at 4% Chrysotile. The VCT floor tile is the last known material at Mt. Rock and was abated the summer of 2018 by First Capital Insulation Inc.

Compliance Management International conducted our triennial re-inspection and management plan on July 28th of 2016. The next triennial inspection is schedule for 2019. Asbestos Hazard Emergency Response Act (AHERA) law requires each school, kindergarten through twelfth grade, to maintain these reports with their asbestos plan, available to the public. A copy of the report is available in the school office and will be made available to the public upon request.